CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-0785:159 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Wheelock Inc., 273 Branchport Avenue, Long Branch, NJ, 07740

Contact: Luy Nguyen (732) 222-6880 Fax (732) 222-5607

DESIGN: Synchronized or Non-Synchronized High Instensity Remote Strobe Lights. Models *RSS-

24150C, *RSS-24177C, RSS-24150CR, RSS-24177CR, RSS-24150W, RSS-24177W, RSS-24185W, *RSSP-24150C, *RSSP-24177C, RSSP-24150CR, RSSP-24177CR, RSSP-24150W, RSSP-24177W, RSSP-24185W. Units may be followed by two alpha or numeric characters indicating lettering and product color. Refer to listee's data sheet for

additional detailed product description and operation considerations.

RATING: Electrical: 24 = 16-33 VDC/VFR

Flash rate: 60 flashes/minute

Candela: Wall = 150cd, 177cd, 185cd

Celing = 150cd, 177cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and

ordinances and in a manner acceptable to the authority having jurisdiction. Models with suffix W are for wall mount only. Models with suffix *CR are for ceiling mount *round

grilles only. All models are for indoor use only.

MARKING: Listee's name, model number, electrical/candela rating and UL label.

APPROVAL: Listed as strobe lights suitable for the hearing impaired when used with separately listed

electrically compatible fire alarm control units. For synchronized strobes, Models SM-12/24, SMX-12/24, DSM-12/24 or DSMX-12/24 Sync Control Module (CSFM Listing No. 7300-0785:132) or PS-12/24-8 Power Unit (CSFM Listing No. 7315-0785:149) must be used.

If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control units must be used with appliances that can generate the temporal pattern signal. Refer to listee's

Installation Instructions Manual for details

*Corrected 03-15-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: MARCH 15, 2003 Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager